

Weight ____660 lbs.
Shell Thickness __10 gauge ____
Head Thickness __10 gauge

NOTICE
THIS PRINT AND THE INFORMATION CONTAINED HEREIN IS PROPRIETARY TO ACE TANK & EQUIPMENT CO. AND SHALL NOT BE REPRODUCED
OR DISCLOSED IN WHOLE OR IN PART, NOR USED FOR ANY DESIGN OR
MANUFACTURING PURPOSES, UNLESS AUTHORIZED IN WRITING BY ACE
TANK & EQUIPMENT CO.

Openings are female NPT and are bushed to size indicated by using nylon bushings per sti- P_3 ® specifications. Before coating, tank shall be tested and proved tight under a test pressure between 5 and 7 psi. Exterior coating per sti- P_3 ® specs.

Tanks shall be built in accordance with UL-58 specifications and shall bear the UL and sti-P₃® labels.

ACE TANK & EQUIPMENT CO. SEATTLE PORTLAND HAYWARD		
FOR:		
JOB:		
NOT TO SCALE		REQUIRED
INVOICE #	DATE	SALESPERSON

Drawing not to scale. Weights & measurements are approximate.

CUSTOMER APPROVAL SIGNATURE